


# Efficient Heat Supply for Industry

Thomas Grube, Alexander Otto, Giacomo Taubert,  
Peter Markewitz, Martin Robinius, Detlef Stolten

Conference „Erneuerbare Wärme für die Energiewende“  
Paris/La Défense, April 26, 2017


# The German Industry in 2012\*

## Electricity use<sup>[1]</sup>




**560 TWh**  
(Net-electricity)

## Fuel use<sup>[1]</sup>



**13.4 EJ**  
(Domestic energy use)

## GHG emissions<sup>[2]</sup>



**939 million t CO<sub>2</sub>-eq**  
(w/o land use and forestry)



## Industry: 1/3 of GHG emissions in Germany



- Electricity use: **226 TWh**
- Electricity generation in industry: **39 TWh**
- **33 %** of „public electricity“
- Fuel demand: **3.1 EJ**  
(incl. material use and power plants)
- GHG- emissions: **333 million t CO<sub>2</sub>-eq**  
(incl. public electricity and heat generation)

[1] Arbeitsgemeinschaft Energiebilanzen (AGEB): *Energiebilanzen der Bundesrepublik Deutschland - Jahre 1990-2012*

[2] Umweltbundesamt: *Nationaler Inventarbericht zum Deutschen Treibhausgasinventar 1990 - 2012*, Dessau-Roßlau, 2014

\*Source: Otto, A.; Ortwein, A.; Zunft, S.; Grube, T.; Kaiser, J.; Krause, M.; Platzer, W.; Schneider, E.; Tänzer, G.; Schneider, C.; Krönauer, A.; ; Wärme und Effizienz für die Industrie. FVEE – Jahrestagung 2015 : Forschung für die Wärmewende, Berlin, 2015

# Heat Demand in Industry in 2012



\*incl. biomass share in waste

↓

<u>Energy use TWh:</u>	
Fuels:	492
<u>Electricity:</u>	<u>42</u>
	534



CO<sub>2</sub> emissions in industry<sup>[1]</sup>  
 Related to heat provision: **159 million t**

[1] Datenbasis: Studie für die Arbeitsgemeinschaft Energiebilanzen e.V. (AGEB): Erstellung von Anwendungsbilanzen für das Jahr 2012 für das verarbeitende Gewerbe mit Aktualisierungen für das Jahr 2009-2011, Karlsruhe 2013.

# Selection of Alternative Technologies

## Heat generation technologies

- Criterion: option of fossil free operation
  - Heat pumps
  - Electrode boilers

## Alternative fuels

- Criterion: transport via existing infrastructure
  - Bio-methane
  - Methane hydrogen blends in the gas grid
  - Synthetic methane

## Technologies for waste heat utilization

- Criterion: high rate of utilization in desired temperature range
  - ORC plants
  - Plants for supplying remote heat from waste heat

# Alternative Heat Supply Technologies

## Electrode boiler

- $\eta = 0.99$  [1]
- $< 240$  °C [2]
- Specific invest: 100–200 €/kW [3]
- Available power range:  $< 60$  MW [4]

## Heat pumps

- $\epsilon_{WP} = 2.4–5.3$  → assumption: 3.85 [5]
- $< 100$  °C [6]
- Specific invest: 200–250 €/kW [6]
- Available power range: 0.02–20 MW [6]

[1] H. Bechem: *Potenziale für Strom im Wärmemarkt bis 2050 : Wärmeversorgung in flexiblen Energieversorgungssystemen mit hohen Anteilen an erneuerbaren Energien ; Studie der Energietechnischen Gesellschaft im VDE (ETG) (2015)*. 2015. [2] F. Biedermann und M. Kolb: *Power to Heat*. Arbeitsgemeinschaft der Hessischen Industrie- und Handelskammern, 2014. [3] D. Fürstenwerth: *Power-to-Heat zur Integration von ansonsten abgeregeltem Strom aus Erneuerbaren Energien : Handlungsvorschläge basierend auf einer Analyse von Potenzialen und energiewirtschaftlichen Effekten ; Studie*. 2014; [4] Parat: *Hochspannungs Elektrodenkessel von Energie zu Wärme für Dampf und Heißwärme*. PARAT Halvorsen AG; [5] J. Lambauer, U. Fahl, M. Ohl, et al.: *Industrielle Großwärmepumpen - Potenziale, Hemmnisse und Best-Practice Beispiele*. IER Stuttgart, 2008; [6] S. Wolf, U. Fahl, M. Blesl, et al.: *Analyse des Potenzials von Industrierwärmepumpen in Deutschland*. IER, 2014; [7] M. Rudolph: *Energieanwendungstechnik : Wege und Techniken zur effizienteren Energienutzung*. 2008.

# Alternative Fuels

## Bio-methane

- Biogas upgraded to grid quality
- Unused potential: 125 PJ [2]
- Levelized cost of bio gas: 5.5–6.5 ct/kWh [2]
- Upgrading cost: 0.7–2.3 ct/kWh [2]

## Power-to-Gas

- Gas production from electric power based on electrolysis (and methanation)
- *Hydrogen* via water electrolysis ( $\eta = 0.7$ )
- Specific invest: 720 €/kW<sub>H<sub>2</sub></sub>
- max. concentration in gas grid: 3.5 Vol.% [4]
- *synthetic methane* via Sabatier process ( $\eta = 0.8$ )
- Specific invest: 720 €/kW<sub>CH<sub>4</sub></sub> [4]

[1] <http://www.union-instruments.com/images/slideshow/anwendungen/anwendungen-header-biogas.jpg> [06.12.2016]

[2] P. Adler, E. Billig, A. Brosowski, et al.: *LEITFADEN BIOGASAUFBEREITUNG UND -EINSPEISUNG*. Fachagentur Nachwachsende Rohstoffe e. V. (FNR), 2014.

[3] <http://www.rwe.com/web/cms/mediablob/de/1768926/data/2/blob.jpg> [06.12.2016]

[4] S. Schiebahn, T. Grube, M. Robinius, et al.: *Power to gas: Technological overview, systems analysis and economic assessment for a case study in Germany*. International Journal of Hydrogen Energy, 40, 4/6/. 2015. S. 4285-4294.

# Technologies for Waste Heat Utilization

## ORC plants

- Waste heat temperature: 80–350 °C [1]
- Efficiency: 0.08–0.20 [1]
- Specific invest: 1000–3000 €/kW<sub>el</sub> [2]
- Available in power range: 0.2–10 MW<sub>el</sub> [2]

## Remote heat supply

- Required waste heat temperature: 80–350 °C [1]
- Efficiency: 0.95 [3]
- Limited data available
- Invest (project in Sindelfingen/DE): 1.5 million € [4]
- Power: 2.5 MW [4]

[1] L. Grote, P. Hoffmann und G. Tänzer: *Abwärmenutzung - Potentiale, Hemmnisse und Umsetzungsvorschläge*. IZES gGmbH (Institut für ZukunftsEnergieSysteme), 2015.

[2] A. Kessler und M. Blesl: *Energieeffizienz in der Industrie*. Berlin: Springer Vieweg, 2013.

[3] W. Schmitz und V. Linckh: *Abwärmenutzung im Betrieb, bayrisches Landesamt für Umwelt*. Bayerisches Landesamt für Umwelt (LfU), 2012

[4] Dr. M. Pehnt, J. Bödeker, M. Arens, et al.: *Die Nutzung industrieller Abwärme – technisch-wirtschaftliche Potenziale und energiepolitische Umsetzung*. 2010.

[5] [http://www.migocon.de/images/gekaufteBilder/Fotolia\\_31060189\\_S.jpg](http://www.migocon.de/images/gekaufteBilder/Fotolia_31060189_S.jpg) [06.12.2016]

- Available data: End energy use for heat supply, Efficiency of technologies, Heat demand shares ordered by temperature range, CO<sub>2</sub> emissions factors of end energy carriers
- Target: Structured end energy use by temperature including CO<sub>2</sub> emissions factors
- Methodology:
  1. Determine end energy use of supplied heat quantity
  2. Distribute heat quantities to temperature ranges based on available data
  3. Determine end energy use ordered by temperature using assumed efficiencies of heat generation
  4. Assumptions regarding fuel use according to temperature requirements



# Results for Process Heat below 100 °C (Values for Germany)

## End energy use

	Process heat (PW) < 100 °C			
	$W_{el}$ TJ	$W_{RH}$ TJ	$W_{th,CHP}$ TJ	$W_{th,dedic}$ TJ
Quarrying, other mining	295	46	498	6,488
Food and tobacco	4,340	3,902	11,937	37,584
Paper & paper products	27	5,691	14,546	10,911
Basic chemicals	48,803	3,836	2,644	1,082
Other chemical industry	94	5,770	3,613	2,393
Rubber and plastic prod.	473	1,421	352	2,845
Glass and ceramics	29	98	132	1,593
Mineral processing	-	-	-	-
Manuf. of basic metals	-	204	533	12,538
Non-ferrous metals	-	85	451	2,391
Metal processing	-	-	-	-
Manuf. of machinery	-	1,049	761	5,289
Manuf. of transport equip.	-	4,963	1,098	9,557
Other segments	-	3,697	5,576	14,930

## Heat supply

	Process heat (PW) < 100 °C			
	$Q_{el}$ TJ	$Q_{RH}$ TJ	$Q_{th,CHP}$ TJ	$Q_{th,dedic}$ TJ
Quarrying, other mining	295	46	537	5,839
Food and tobacco	4,340	3,902	12,053	33,826
Paper & paper products	27	5,691	14,060	9,820
Basic chemicals	48,803	3,836	2,857	974
Other chemical industry	94	5,770	3,926	2,154
Rubber and plastic prod.	473	1,421	804	2,560
Glass and ceramics	29	98	73	1,433
Mineral processing	-	-	-	-
Manuf. of basic metals	-	204	662	11,284
Non-ferrous metals	-	85	1,029	2,152
Metal processing	-	-	-	-
Manuf. of machinery	-	1,049	1,736	4,760
Manuf. of transport equip.	-	4,963	2,506	8,601
Other segments	-	3,697	4,760	13,437

<b>Total</b>	54,061	30,762	42,142	107,602
--------------	--------	--------	--------	---------

<b>Total</b>	54,061	30,762	45,004	96,841
--------------	--------	--------	--------	--------


Indices: RH = Remote heat; th,KWK = CHP(Combined heat and power) plants; th,dedic = plants for dedicated heat generation;  
Source own calculations based on data in AGEB: *Energiebilanz der Bundesrepublik Deutschland 2014*. Arbeitsgemeinschaft Energiebilanzen e.V., 2016.

# Results of Structuring End Energy Use (Values for Germany)

- 15 % (250 PJ) of fuel use allocated to combined heat and power generation (CHP)
- 85 % (1,300 PJ) of all fuels are used in plants for dedicated heat provision (boilers and ovens) and supply 1,100 PJ of heat
- Up to 100 °C 390 PJ and up to 240 °C 750 PJ heat are supplied from fuels and remote heat
- **Technical potential of heat pumps is estimated with 390 PJ**
- **Technical potential of electrode boilers is estimated with 750 PJ**
- In 2014 a total of 163 million t CO<sub>2</sub> are caused by heat supply in industry

# Waste Heat Quantities Ordered by Temperature

- Difference of fuel use in plants for dedicated heat supply and total heat supply considered as waste heat: 207 PJ



Waste heat carried in flue gases in Germany, accounted for in accordance with 11. BImSchV (Federal Emissions Protection Regulation) [1]

- Waste heat classified by temperature
- 35 – 80 °C      20 PJ
- 80 – 350 °C    164 PJ
- >350 °C        23 PJ

[1] A. Otto, T. Grube, A. Ortwein, et al.: *Wärme und Effizienz für die Industrie*. 2015.

# Method of Assessment

## CO<sub>2</sub> reduction potential

- Determine technical potential of alternative technologies
- Calculate difference of specific CO<sub>2</sub> emissions factors

## Economic analysis

- Determine heat, electricity and fuel supply cost of alternative and conventional technologies in accordance with VDI rule 2067 [1]
- CO<sub>2</sub> avoidance cost employing CO<sub>2</sub> reduction potentials and economic analysis

## Scenarios

- Scenario 1 → Electricity mix (cost of electricity: 116 €/MWh<sub>el</sub>; availability not limited; operational hours: 7000 / 7500 h/a; CO<sub>2</sub> emissions factor: 164 t<sub>CO2</sub>/TJ) [2]
- Scenario 2 → Electricity from wind (cost of electricity 74 €/MWh<sub>el</sub>; limited availability; 2143 annual full-load hours; no emissions) [3,4,5,6,7]

[1] VDI: *Wirtschaftlichkeit gebäudetechnischer Anlagen Grundlagen und Kostenberechnung VDI 2067*. Verein Deutscher Ingenieure e.V., 2012.

[2] Eurostat: *Preise Elektrizität für Industrieabnehmer, ab 2007 - halbjährliche Daten*. Verfügbar unter: [http://appsso.eurostat.ec.europa.eu/nui/show.do?dataset=nrg\\_pc\\_205&lang=de](http://appsso.eurostat.ec.europa.eu/nui/show.do?dataset=nrg_pc_205&lang=de) [22.11.2016].

[3] S. Schiebahn, T. Grube, M. Robinius, et al.: *Power to gas: Technological overview, systems analysis and economic assessment for a case study in Germany*. International Journal of Hydrogen Energy, 40. 4/6/. 2015. S. 4285-4294.


[4] o. V.: *Energiekosten in Deutschland - Entwicklungen, Ursachen und internationaler Vergleich*. frontier economics, 2010.

[5] BWE: *Installierte Windenergieleistung in Deutschland*. 2015. Verfügbar unter: <https://www.wind-energie.de/infocenter/statistiken/deutschland/installierte-windenergieleistung-deutschland> [22.11.2016].

[6] S. Lüers und K. Rehfeldt: *Status des Offshore-Windenergieausbaus in Deutschland*. Deutsche WindGuard GmbH, 2016.

[7] P. Graichen, M. M. Kleiner und C. Podewils: *Die Energiewende im Stromsektor: Stand der Dinge 2015*. Agora Energiewende, 2016.

# CO<sub>2</sub> Reduction Potentials of Alternative Technologies




## CO<sub>2</sub> reduction potentials

- Heat pumps, S1: 9 Mt<sub>CO<sub>2</sub></sub>
- Electrode boilers, S2: 22 Mt<sub>CO<sub>2</sub></sub>
- Heat pumps, S2: 26 Mt<sub>CO<sub>2</sub></sub>
- Combined technologies, S2: 42 Mt<sub>CO<sub>2</sub></sub>

Source: own calculations

# CO<sub>2</sub> Reduction Potentials of Alternative Fuels



## CO<sub>2</sub> Reduction potentials

- Hydrogen, S2: 0,6 Mt<sub>CO2</sub>
- Synth. methane, S2: 10 Mt<sub>CO2</sub>
- Bio-methane: 5 Mt<sub>CO2</sub>

Source: own calculations based on:

[1] S. Schiebahn, T. Grube, M. Robinius, et al.: *Power to gas: Technological overview, systems analysis and economic assessment for a case study in Germany.*

[3] R. Edwards, J.-F. Larivé, D. Rickeard, et al.: *WELL-TO-TANK Appendix 2 - Version 4a Summary of energy and GHG balance of individual pathways.* European Commission, 2014.


[4] C. Bensen: *Biomethan : Potenziale, Gas-Aufbereitung und Netzeinspeisung.* 2013.

## CO<sub>2</sub> Reduction Potentials of Waste Heat Utilization

- Waste heat quantities in desired temperature range of ORC plants and plants for remote heat supply: 164 PJ
- Energy quantities available for heat supply
  - 23 PJ<sub>el</sub> via ORC
  - 156 PJ<sub>th</sub> via remote heat
- Resulting CO<sub>2</sub> reduction potentials
  - 4 million t<sub>CO2</sub> related to ORC
  - 10 million t<sub>CO2</sub> related to remote heat

- Levelized cost of heat supply depend on plant capacity via capital and operational cost
- Cost degression:  $\frac{I_1}{I_2} = \left(\frac{X_1}{X_2}\right)^m$

[1]



[1] W. Wagner: *Planung im Anlagenbau*. 2009.



# Economic Performance of Alternative Heat Supply Technologies

Technology	Levelized heat cost €/MWh <sub>th</sub>	Average heat cost, €/MWh <sub>th</sub>	CAPEX €/MWh <sub>th</sub>	OPEX €/MWh <sub>th</sub>	Demand driven cost €/MWh <sub>th</sub>	Other cost €/MWh <sub>th</sub>
Gas boiler <sup>1</sup>	37–38	37	0.2–.4 (0.5 %–3.5%)	0.07–0.51 (0.2 %–1.3 %)	36 (99 %–95 %)	0.02–0.2 (0.1 %–0,4 %)
Condensing boiler <sup>1</sup>	35–42	38	0.6–2.4 (1.8 %–5.8 %)	1.8–7.1 (5.3 %–17 %)	32 (93 %–77 %)	0.06–0.2 (0.2 %–0.6 %)
Electrode boiler, S1	120–127	123	1.5–4.4 (1.2 %–3.4 %)	0.43–1.3 (0.4 %–1.0 %)	117 (97 %–92 %)	1.4–4.3 (1.2 %–3.4 %)
Heat pump, S1	34–35	34	2.9–3.6 (8.6 %–10 %)	0,71–0,89 (2.1 %–2.6 %)	30 (89 %–86 %)	0.3–0.4 (0.8 %–1.0 %)
Electrode boiler, S2	79–93	86	4.8–14 (6.0 %–15 %)	1.4–4.2 (1.8 %–4.5 %)	73 (92 %–79 %)	0.5–1.4 (0.6 %–1.5 %)
Heat pump, S2	32–35	33	10–12 (30 %–34 %)	2.3–2.9 (7.4 %–8.4 %)	19 (59 %–54 %)	0.9–1.2 (3.0 %–3.4 %)


<sup>1</sup> Natural gas price: 34.5 €/MWh <sup>[2]</sup>

Eigene Berechnung basierend auf

[1] VDI: *Wirtschaftlichkeit gebäudetechnischer Anlagen Grundlagen und Kostenberechnung VDI 2067*. Verein Deutscher Ingenieure e.V., 2012.

[2] Eurostat: *Preise Gas für Industrieabnehmer, ab 2007 - halbjährliche Daten*. <http://ec.europa.eu/eurostat/data/database> [22.11.2016].

# Economic Performance of Alternative Fuel Use





Eigene Berechnung basierend auf

[1] VDI: *Wirtschaftlichkeit gebäudetechnischer Anlagen Grundlagen und Kostenberechnung VDI 2067*. Verein Deutscher Ingenieure e.V., 2012.

[2] S. Schiebahn, T. Grube, M. Robinius, et al.: *Power to gas: Technological overview, systems analysis and economic assessment for a case study in Germany*. International Journal of Hydrogen Energy, 40. 4/6/. 2015. S. 4285-4294.

[3] P. Adler, E. Billig, A. Brosowski, et al.: *LEITFADEN BIOGASAUFBEREITUNG UND -EINSPEISUNG*. Fachagentur Nachwachsende Rohstoffe e. V. (FNR), 2014.

# Economic Performance of Waste Heat Utilization



[1] C. Kost, Mayer, J.N., Thomsen, J., Hartmann, N., Senkpiel, C., Philipps, S., Nold, S., Lude, S., Schlegl, T.: *Stromgestehungskosten Erneuerbare Energien: November 2013*. Fraunhofer ISE, 2013.

[2] VDI: *Wirtschaftlichkeit gebäudetechnischer Anlagen Grundlagen und Kostenberechnung VDI 2067*. Verein Deutscher Ingenieure e.V., 2012.

[3] A. Kessler und M. Blesl: *Energieeffizienz in der Industrie*. Berlin: Springer Vieweg, 2013.

[4] G.Totschnig, J. Radl und A. Ortner: *Highly resolved simulation of feasible pathways to a renewable power system in Germany and Austria – Is storage really a limiting component?* Energy Economics Group TU Wien, 2013.

[5] M. Hille: *Strategieoptionen für Energieversorgungsunternehmen als Reaktion auf einen rückläufigen Absatz im Wärmemarkt*. 2002.

# CO<sub>2</sub> Avoidance Cost

Alternative Technology	CO <sub>2</sub> avoidance cost [€/t <sub>CO2</sub> ]
Heat pump, Scenario 1	-20
Electrode boiler, Scenario 2	135
Heat pump, Scenario 2	-15
Hydrogen, Scenario 2	670
Synthetic methane, Scenario 2	1240
Bio-methane	315
ORC plant	-20
Remote heat supply from waste heat utilization	-35

## Summary and Outlook

- CO<sub>2</sub> emissions from heat supply in industry are currently 163 million t<sub>CO2</sub>
- Maximum reduction potential has been derived with 57 Mt<sub>CO2</sub>

Heat pumps in Scenario 2:	26 million t <sub>CO2</sub>	→	-15 €/t <sub>CO2</sub>
Electrode boiler in Scenario 2:	16 million t <sub>CO2</sub>	→	135 €/t <sub>CO2</sub>
Bio-methane:	5 million t <sub>CO2</sub>	→	315 €/t <sub>CO2</sub>
Remote heat supply from waste heat:	10 million t <sub>CO2</sub>	→	-35 €/t <sub>CO2</sub>

- Further topics to be analysed:
  - Comparison of study results with research project „Abwärmeatlas“
  - Assessment of the use of electrode boilers in the negative balancing power market
  - Assessment of cooling supply in industry

# Vielen Dank für Ihre Aufmerksamkeit

## Abteilung Verfahrens- und Systemanalyse (VSA)



Prof. Dr. Detlef Stolten  
Institutsleiter IEK-3  
d.stolten@fz-juelich.de



Dr. Bernd Emonts  
Stellvertretender Institutsleiter IEK-3  
b.emonts@fz-juelich.de



Dr. Martin Robinius  
Abteilungsleiter VSA  
m.robinius@fz-juelich.de



Dr. Thomas Grube  
Gruppenleiter Mobilität  
th.grube@fz-juelich.de



Dr. Peter Markewitz  
Gruppenleiter Stationäre Energiesysteme  
p.markewitz@fz-juelich.de